

Příloha k PD E2, E4

ČM + účel místnosti	Ochrana dle ČSN 332000-4-41 ed.2	Prostředí dle ČSN 332000-5-51 ed.3	Osvětlení dle ČSN EN 12464-1
201,202 - herna	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	300 lx
203 - herna malá	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	300 lx
204 - odpočinek	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	300 lx
205 - strojovna	TN -S+RCD+SEBT	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
206 - šatna	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
207 - WC	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
208 - hygiena	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
209 - úklid	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	100 lx
210 - šatna	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
211 - chodba	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	100 lx
212 - šatna	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
213 - hygiena	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
214 - WC dětí	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	200 lx
215 - sklad	TN - S + RCD	AA5,AB5,AD1,BA1,CA1,CB1	100 lx
216 - venek	TN - S + RCD	AA8,AB8,AD2,BA1,CA1,CB1	50 lx